

DECLARATION OF CONFORMITY

We, M&M International S.r.l. registered office via A. Appiani 12 – 20121 Milano - Italy, declare under our sole responsibility that the product:

ANALOG ELECTRONIC TIMER M&M SERIES "AT2000"

to which this declaration relates is in conformity with the following EC Regulations and Directives (and their amendments):

- Electromagnetic Compatibility (EMC) - 2004/108/EC Directive (ex 89/336/EC)

Harmonized Technical Standard	Year	Issue	Title
EN 60730-1 + amendment A1 + amendment A12 + amendment A13 + amendment A14 + amendment A15 + amendment A16	2000-11 2004-09 2003-09 2004-09 2005-01 2007-01 2007-04	--	Automatic electrical controls for household and similar use Part 1: General requirements
EN 61000-3-2 +amendment A1 +amendment A2	2006-04 2009-07 2009-07	--	Electromagnetic compatibility (EMC) Part 3-2: Limits – Limits for harmonic current emissions (equipment input current up to and including 16A per phase)
EN 61000-3-3	2008-09	--	Electromagnetic compatibility (EMC) Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current up to and including 16A per phase and not subject to conditional connection.
EN 61000-6-2	2005-08	--	Electromagnetic compatibility (EMC) Part 6-2: Generic standards – Immunity for industrial environments
EN 61000-6-3	2007-01	--	Electromagnetic compatibility (EMC) Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments

- Low Voltage Directive - 2006/95/EC Directive (ex 73/23/EC and amendment 93/68/EC)

Harmonized Technical Standard	Year	Issue	Title
EN 60730-1	2000-11	--	Automatic electrical controls for household and similar use - Part 1: General requirements
EN 60529	1997-06	--	Degrees of protection provided by enclosures (IP Code)

Orio al Serio, Italy, June 2012

The General Manager

Maurizio Forno



ATTENTION!

The attention of the purchaser, installer or user is drawn to special measures and limitations to use that must be observed when the product is used, installed or taken into service. Details of these special measures and limitations to use are available on request and are also contained in the product label and in the Installation, Maintenance and User Instructions provided together with the product.